



General Requirements:

- ✓ The pathway to the eyewash station is clear of obstructions.
- ✓ The eyewash itself is free from any obstructions.
- ✓ Clear water flows from the eyewash jets.
- ✓ No leaks present.
- ✓ Both of the eyewash jets have ample pressure and reach a satisfactory height.

Emergency Eyewash Station Weekly Inspection Checklist

<u>Date</u>	<u>Initials</u>	<u>Date</u>	<u>Initials</u>	<u>Date</u>	<u>Initials</u>	<u>Date</u>	<u>Initials</u>	<u>Date</u>	<u>Initials</u>

NOTE: Post this form by the eyewash station for weekly logging of inspection dates. Contact EHS at ehs@uml.edu if the eyewash station did not pass a weekly inspection.